



# OKLAHOMA CITY COMMUNITY COLLEGE

## SOLICITATION FOR BID ADDENDUM NOTICE

RFP NO. 2-SFB-23-010

ISSUED 06/28/22

CLOSING DATE 07/20/22

CLOSING TIME: 2:00 PM CST

---

Request for Proposal issued by Oklahoma City Community College for Data Center Cooling System.

**NOTE:** *If your company will not be responding, please notify Purchasing and no further addenda will be sent. See original Request for Proposal for Purchasing contact name and email for this solicitation.*

### ADDENDUM #1 – Dated 07/07/2022

This addendum has been issued based on a question and to provide additional information regarding this bid

- 1) A tour of the facilities for this bid has been scheduled for **Tuesday, July 12, 2022 beginning at 10:00am**. Contractors who are interested in attending will meet at the MB1 entrance of the Main Building.
  
- 2) During the pre-bid meeting held on July 7, 2022, a question was asked regarding the number of units. Per the SFB scope:
  - a. Demo/proper disposal of existing Data Air 15 ton system
  - b. Removal of return ducting at existing 15 ton system
  - c. Install two (2) Liebert Model D 10 ton precision cooling systems (down flow AHU)
    - i. Substitutions to the Liebert units will be considered and reviewed
  - d. Install two (2) Liebert Model MC 10 ton air cooled condensers located on the roof of the Science, Engineering, and Math Center (SEM)
    - i. Substitutions to the Liebert units will be considered and reviewed

Purchasing Department

Phone 405-682-7593 – Fax 405-682-7568 – 7777 South May Avenue, Oklahoma City, OK 73159